

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO....1101

Dated...12.06.25

It is certified that an inspection team headed by Iftelkhar Ansari.....Junior Engineer
(Name of Officers with designation) From Nagar Parishad, Kishanganj. PHED inspected the
Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj, Bihar Pin-855107 (Name & Address
of the School) on04.6.25..... (date of inspection) and on the basis of Water Test
Report Attached bearing no....1101....dated-.....12.06.25of District Level Water Testing
Laboratory under P.H.Division Kishanganj Certified that the **Saraswati Vidya Mandir** (Name
of School) has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building &
the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

Iftelkhar Ansari
04/06/25
JE

Signature with seal:

Name:- Sunil Kumar Deepak

Designation :- Executive Engineer

Sunil Kumar Deepak
04/06/25
Executive Engineer
PH Division Kishanganj

Name & Address of the Office/Department :- Public Health Division, Kishanganj

To,

Saraswati Vidya Mandir,
Motibagh, Teusa,
Kishanganj, Bihar
Pin-855107
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

DISTRICT LEVEL WATER TESTING LABORATORY


UNDER


P.H. DIVISION KISHANGANJ


Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

Sample Collected By : - School Staff								Date of Sample Submitted in Lab :- 29.05.2025						
District-Kishanganj								Date of Reporting :- 04.06.2025						
Sl.No	Block	Panchyat	Location	Turb.	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj (Hand Pump)	2.17	7.24	0.63	40.8	43.56	8.16	4.95	15.76	104	68	
2	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj (Treated Water)	1.09	6.96	0.47	69.36	63.36	16.32	6.94	45.33	227	147	
Desirable limit				1 NTU	6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	---	500 mg/l	
permissible Limit in absence of alternate source IS:10500 :2012				5 NTU	NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	μ mhos/cm	2000 mg/l	

NR- No Relaxation


 04/06/25
 Lab.Assistant
 P.H. Division Kishanganj


 04/06/25
 Chemist
 P.H.Division Kishanganj


 04/06/25
 Assistant Engineer
 P.H.Sub. Division Kishanganj

